## The Lyceum School – Fire Risk Assessment

Significant Hazards	People who are at risk from hazards	Existing Controls and risks not adequately controlled	What further action is needed?
Ground floor – Early Years Unit /Office/Entrance Hall Use of electrical equipment and storage/use of paper	Staff/pupils/visitors	-Electrical supply turned off when not required. -Appropriate storage of paper and management of waste paper. -Area fully alarmed. -Evacuation procedure/alarm point in entrance hall.	Low risk
<u>Ground floor – Gallery/</u> <u>Music Rooms/Storage cupboards</u> Area used for whole school assemblies with visitors – need for efficient evacuation in an emergency.	Staff/pupils/visitors	-2 clearly marked emergency exits with standard escape signs. -Area fully alarmed and covered by emergency lighting.	Low risk
<u>Ground floor – Courtyard (play</u> <u>area)/Costume store/</u> <u>Main staircase</u> Undetected fire in costume store	Staff/pupils/visitors	-turn off ignition source (lighting) whenever possible. -detector alarm fitted.	Low risk
Rear landing/Emergency Exit Door and Staircase Emergency staircase not available during evacuation due to fire in area below stairs caused by main fusebox.	Staff/pupils/visitors	-no combustible material stored beneath stairs.	Low risk Action point: Mains electric Circuit box to be encased.

## The Lyceum School Fire Risk Assessment (Continued)

Basement Classrooms/Offices Use of electrical equipment and storage/use of paper	Staff/pupils/visitors	-Electrical supply turned off when not required. -Appropriate storage of paper and waste paper management. -Area alarmed.	Low risk
Basement – Staff Room/Pupil Sick Bay Extra electrical equipment including cooker.	Staff/pupils/visitors	-Electrical supply turned off when not required. -Fire blanket kept near cooker.	Low risk
Basement – Café (lunch room)/ Storage cupboard Electrical equipment and storage of craft materials/paint.	Staff/pupils/visitors	-Electrical supply turned off when not required. -Electrical supply and storage area at opposite ends of room. -Area alarmed – fire extinguishers stored nearby.	Low risk